DN	$1 \wedge$		5	
----	------------	--	---	--

TYPE APPROVAL CERTIFICATE

Certificate No: **TAE00002BA**Revision No:

I b	16 16	e to	COL	******
	19 18	o LU	CCI	tify:

That the Electric Power Cable

with type designation(s)

LM-HF (1XZ1-R, 1XZ1-K), LSM-HF (1XC4Z1-R, 1XC4Z1-K), LSM-HF EMC (1XC7Z1-R, 1XC7Z1-K, 1XC4Z1-R)

Issued to

Türk Prysmian Kablo ve Sistemleri A.S. Bursa, Turkey

is found to comply with

DNV GL rules for classification – Ships, offshore units, and high speed and light craft DNV GL class programme DNVGL-CP-0399 – Type approval – Electric cables

Application:

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.

Туре	Rated voltage (kV)	Temp. class (°C)
LM-HF (1XZ1-R, 1XZ1-K)	0,6/1	90
LSM-HF (1XC4Z1-R, 1XC4Z1-K)	0,6/1	90
LSM-HF EMC (1XC7Z1-R, 1XC7Z1-K, 1XC4Z1-R)	0.6/1	90

Issued at Høvik on 2019-05-09

for **DNV GL**

This Certificate is valid until **2023-04-10**.

DNV GL local station: Istanbul

Approval Engineer: **Georgy Abramenko**

Trond Sjåvåg Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



n code: TA 251 Revision: 2016-12 www.dnvgl.com Page 1 of

Job Id: **262.1-028622-2** Certificate No: **TAE00002BA**

Revision No: 2

Product description

Power cables designed according to IEC 60092-353.

Construction:	
Conductors:	-R types: Stranded copper conductor class 2
	-K types: Flexible stranded copper conductor, class 5.
Core insulation:	HF XLPE
Inner covering:	LSOH filler/ LSOH inner covering or tape
Metal covering:	Bare copper wire braiding
Screen:	Electro Magnetic Compatible (EMC) 100% covered copper tape screen (EMC cables
	only)
Outer sheath:	SHF1

No of cores:	Cross sectional area [mm ²]	
1 to 4	1,5 to 300	
5	1,5 to 50	
6 to 60	1,5 to 4	

Application/Limitation

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

Type Approval documentation

Data sheets: B.3: LV FLAME RETARDANT EMC SCREENED POWER CABLES(CLASS 2)

Test report: Türk Pirelli GE-01E and Q/LV3253, Türk Prysmian Kablo EI-13-16, dated 05.04.2013

Tests carried out

Standard	Issued	General description	Limitation
IEC 60092-350	2014-08	General construction and test methods of	
		power, control and instrumentation cables for	
		shipboard and offshore applications	
IEC 60092-353	2011-08	Electrical installations in ships - Part 353: Power	0,6/1 kV
		cables for rated voltages 1 kV and 3 kV	
IEC 60092-360	2014-04	Electrical installations in ships - Part 360:	
		Insulating and sheathing materials for shipboard	
		and offshore units, power, control,	
		instrumentation and telecommunication cables.	
IEC 60332-1-2	2004-07	Tests on electric and optical fibre cables under	
		fire conditions - Part 1-2: Test for vertical flame	
		propagation for a single insulated wire or cable	
IEC 60332-3-22	2009-02	Tests on electric and optical fibre cables under	Bunch test
		fire conditions – Part 3-22: Test for vertical	Category A
		flame spread of vertically-mounted bunched	
		wires or cables – Category A	
IEC 60754-1	2011-11	Test on gases evolved during combustion of	Low Halogen:
		materials from cables – Determination of the	<0,5% Halogen
		amount of halogen acid gas	

Form code: TA 251 Revision: 2016-12 www.dnvgl.com Page 2 of 3

Job Id: **262.1-028622-2** Certificate No: **TAE00002BA**

Revision No: 2

Standard	Issued	General description	Limitation
IEC 60754-2	2011-11	Test on gases evolved during combustion of	Halogen free:
		materials from cables – Determination of the	pH > 4,3
		degree of acidity of gases evolved during the	Conductivity < 10µS
		combustion of materials taken from electric	
		cables by measuring pH and conductivity	
IEC 61034-1/2	2013-07	Measurement of smoke density of cables	Low smoke. Light
	2013-09	burning under defined conditions –	transmittance >60%
		Test apparatus, procedure and requirements	

Marking of product

Prysmian – type – size – 0,6/1 kV – year – meter.

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE

Form code: TA 251 Revision: 2016-12 www.dnvgl.com Page 3 of 3